

TARGET STATION FACILITY SAFETY ASPECTS

ESSNUSB WORKING GROUP SESSION
ESSNUSB WP4 / EURONUNET WG2 - TARGET STATION


TARGET STATION FACILITY - GLOBAL WORKING PLANS



Target Station Facility Sub-Systems

Target Station

- Target + integration
- Horn
- Four Horn Support
- Proton Beam extraction



Power Supply System

- Target Station
- Power Supply Unit
- Cooling System
- Stripline Connection




Fluid System

- Closed cooling Fluid (Helium gas, Water)
- Radioactive Effluents
- Confinement System



Handling and Logistic

- Active Cell
- Casks
- Remote Handling




TARGET STATION FACILITY - GLOBAL WORKING PLANS



Target Station Facility Sub-Systems


Target Station

- Target + integration
- Horn
- Four Horn Support
- Proton Beam extraction



Power Supply System

- Target Station
- Power Supply Unit
- Cooling System
- Stripline Connection



Fluid System

- Closed cooling Fluid (Helium gas, Water)
- Radioactive Effluents
- Confinement System



Handling and Logistic

- Active Cell
- Casks
- Remote Handling





- **Safety : Preparation Phase ↔ Design Study**
 - **Non-radiological risks**
 - **Electrical risk, cooling system, maintenance operation....**
 - **Earthquake**
 - **Radiological risks**
 - **Determine the radiological risks (external or internal contamination) for each part of the facility.**
 - **Investigate biological protections with respect to the prompt dose and residual dose**
 - **Environnemental impact studies (Tritium, ^{22}Na ,..)**

TARGET STATION FACILITY - GLOBAL WORKING PLANS

ALARA Approach:

Anticipate and reduce individual and collective exposition to radiations.



Building “rooms”

- Open Top geometry for the Target Station Room, Decay Tunnel, Beam Dump
- Hot Cell (Repair Target Station elements)
- Morgue (Store radioactive wastes)
- Horn Power Supply Room , Power supply outside of the main building ?

=> **Energy Deposition and Dose Rate Estimation with FLUKA Simulation**


Feedback from previous experiments is crucial

As Low As Reasonably Achievable

TARGET STATION FACILITY

Building Structure:


- Proton Driver line
- Experimental Hall
 - MW Target Station
 - Decay Tunnel
 - Beam Dump
- Maintenance Room
- Service Gallery
 - Power supply
 - Cooling system
 - Air-Ventilation system
- Waste Area



TARGET STATION FACILITY

MW Target Station :

- Focusing System
- Crane System
- Automated robot
- Mechanical structure for the for horn
- Dose Rate Monitoring System
- Residual Dose Rate Platform
- Operation under helium Atmosphere
 - flushing with air
 - filter to measure radioactive pollution (dust, tritium ...)
- Investigation of other radionucleides transport (environmental constraint)
- ...





Non Radiological Risks

TARGET STATION


Four horns station:

- Solid Static target (Titanium)
- Use multiple 4 targets+ horns
- Beam frequency 56 Hz
- Cooling
- Power distribution due to Joule losses & secondary particles
- Energy balance, to maintain working temperature
- Flow rate
- Jet distribution along the outer conductor
- h correlation for jets' geometry



TARGET STATION

- **Recommendations from others facilities:**
 - Cracks in welds
 - Use flexible pipes to reduce stress and fatigue
 - Water leaks due to galvanic corrosion => avoid trapped water and choose material carefully
 - Use semi flexible conductor because of important magnetic force between stripline => can break cable
 - Heat dissipation of the stripline
 - Remote design for repairing/exchange
 - Need Spares
 - ...



Striplines plate with soft transition

HORN INVESTIGATION FAILURES

Failure	Causes	Consequences	Solution	Action/Safety
Cracks, weld junction	Material faults In the weld junction	Water leaks Current discontinuity	Check quality of weld junctions	Electrical shutdown Water flow shutdown
Cracks in the aluminium all, pipes connections	Peak stress too high	Water leaks Large displacement Crack growth Horn destruction	Stress analysis of the pipes connections; Of the details connections	Electrical shutdown Water flow shutdown
Cracks in the aluminium wall	High cyclic stress Fatigue cracks	Water leaks Large displacement Crack growth	R&D studies	Electrical shutdown Water flow shutdown
Striplines/horn connection cracks	Localised high cyclic Stress Corrosion Fatigue cracks	Electrical discontinuity Change in the magnetic field	R&D studies in the stripline horn/connection	Electrical shutdown Water flow shutdown
Striplines/connections Cracks initiation	Stress corrosion	Electric resistance increase	R&D studies	Electrical shutdown

COMPLEMENTARY INFRASTRUCTURE (FEEDBACK)

SPL Cooling system :

Conceptual design of the SPL II, A high-power superconducting H- linac at CERN – CERN-2006-006 - 12 July 2006




Table 5.5: Primary cooling needs and cooling-circuit parameters

	ΔT [K]	Power [MW]	ΔP [bar]	Flow rate [m³/h]
Primary cooling SPL	9	16.8	5	1600
Cryo-compressors	5.7	4.0	5	600


Table 5.6: Secondary cooling circuits

Item	Fluid	Power [kW]	P_{max} [bar]	ΔT [K]	Flow rate [m³/h]
Klystron	Demineralized water	11000	8.5	7.5	1300
RF loads	Demineralized water	4500	8.5	20	200
RT cavities	Demineralized water	800	8.5	10	70
Magnets (quadrupole)	Demineralized water	100	12	15	6
Magnets (bending)	Demineralized water	300	12	15	17
Dump linac	Demineralized water	100	12	15	6

*Schematic diagram of the main cooling plant

Complementary plants needed for

- cooling the 4 horns, decay tunnel and beam dump
- cooling and recirculating helium inside the vessel



IPAC'17 Proceedings: E. Bouquerel et al, "Energy deposition and activation studies of the ESSnuSB Horn Station", MOPIK029

COMPLEMENTARY INFRASTRUCTURE (FEEDBACK)

POWER SUPPLY:

Conceptual design of the SPL II, A high-power superconducting
H- linac at CERN – CERN-2006-006 - 12 July 2006




Fig. 5.9: Layout of CERN's standard 66/18 kV substation




Fig. 5.10: Proposed electrical distribution system for the SPL

**Complementary plants needed for the
super beam infrastructure**

- alimentation station for the horns
- air conditioning installation

Table 5.9: Electrical power requirements (MW) of the SPL (r.m.s. values)

Load	4 MW neutrino	5 MW EURISOL
	baseline	baseline
RF system†	20.2	24.4
Cryogenics	3.6	4.4
Cooling and ventilation	4	4
Other	1	1
General services (surface + tunnel), racks, computers, controls	3	3
Total	32	37

† Including 30% margin to compensate for Lorentz-force detuning in the SC cavities.

Radiological Risks

TARGET STATION FACILITY

Chemical composition of Material*:

Target => Ti(100%)

Horn => Anticorodal 110 alloy

Al (95.5%), Si(1,3%), Mg(1,2%), Cr(0.2%),
Mn(1%), Fe (0.5%), Zn(0.2%), Cu(0.1%)

Decay Pipe => Steel P355NH


Fe(96.8%), Mn(1.65%), Si(0.5%), Cr(0.3%),
Ni(0.3%), C(0.2%)

Tunnel => Concrete

O(52.9%), Si(33.7%), Ca(4.4%), Al(3,49%),
Na(1,6%), Fe(1.4%), K(1,3%), H(1%),
Mn(0.2%), C(0.01%)

Surrounding Environment => Molasse

O(49%), Si(20%), Ca,(9.7%), Al(6.4%),
C(5%), Fe(3.9%), Mg(3.2%), K(1%),
Na(0.5%), Mn(0.1%)



Four horn station layout

*TO BE UPDATE FOR ESSNU SB

RADIATION SIMULATION (FROM EURONU)

Beam Features

- Proton Energy : 4.5 GeV/c
- Intensity : $5.55 \cdot 10^{15}$ pps
- Irradiation time : 200 days

Target:

- Material : Titanium
- Density : 3.g/cm³
- Cylinder : 78 cm x 30mm


Horn:

- Material : Anticorodal 110

Activation Target + 4-Horns:




- Targets
- Horns
- Lateral Iron shield
- Lateral Concrete

⇒ Activation Study performed under FLUKA 2011.2.3






RADIATION SIMULATION (FROM EURONU)

Evolution of the target activity with cooling time:




RADIATION SIMULATION (FROM EURONU)

Evolution of the horn activity with cooling time:



RADIATION SIMULATION (FROM EURONU)

Radionucleides in main horn (Cooling times 1 day) after 200 days of running:







Four Horns System

**Top Right Horn Irradiated
at 1MW**

Radionucleide s	T _{1/2}	Spec. Avt Bq/g	Vol. Act Bq/cm ³
⁷ Be	53.22 d	2.37E+07	6.5201e+12
²⁴ Na	14,96 h	2.31E+07	6.3366e+12
²² Na	2,6 y	6.39E+06	1.7549e+12
³ H	12.312 y	5.31E+06	1.4582e+12
...

Activation Levels in the main Horn (1MW)

Evolution of the horn activity with cooling time:



RADIATION LAYOUT FROM EURONU

Simulation Parameters :

Beam Power : 4MW

Irradiation Times : 200 days

One Horn : Geometry Updated

Cooling times : 1d,1w,1m, 6m,1y, 10y

Chemical composition of Material:

Target => Titanium

Horn => Anticorodal 110 alloy

Al (95.5%), Si(1,3%), Mg(1,2%), Cr(0.2%),
Mn(1%), Fe (0.5%), Zn(0.2%), Cu(0.1%)


Decay Pipe => Steel P355NH

Fe(96.8%), Mn(1.65%), Si(0.5%), Cr(0.3%),
Ni(0.3%), C(0.2%)

Tunnel => Concrete


O(52.9%), Si(33.7%), Ca(4.4%), Al(3,49%),
Na(1,6%), Fe(1.4%), K(1,3%), H(1%),
Mn(0.2%), C(0.01%)

Scoring Region : [-200,200]x[-200,200] [-500,500], cell dimension 20cm*20cm*20cm




Radiation layout


DOSE EQUIVALENT RATE (ALL LAYOUT)




After 1day



After 6m




After 1 week




After 1y


DOSE EQUIVALENT RATE CONTRIBUTION (COOLING TIME 1D)




Target Contribution



Horn Contribution





Vessel Contribution



Tunnel Contribution

DOSE EQUIVALENT RATE CONTRIBUTION (COOLING TIME 1D)

From EUROnu



DER Contribution to the dose at 60cm

Fluka parameter Inputs :

Proton Energy : 4.5 GeV
Beam Intensity : 5.56×10^{15} protons
Irradiation times : 200 days

First Step : 10000 Histories
Second Step : 200000 Histories

=> Increase statistics

DER Evolution with distance

Distance (cm)	All	Target	Horn	Vessel	Tunnel*
60	554400	469800	38304	21722.4	82.152
100	240948	213660	15933.6	20746.8	3664.8
140	157716	123372	11300.4	18478.8	418.32

*Vessel act as a shield

DER Estimation mSv/h

NUCLEAR WASTE MANAGEMENT



IAEA Waste Classification:

- **HLW** High Level Wastes
 - Highly Radioactive liquid
 - Heat Generating (>2kw/m³)
- **LILW** Low and Intermediate Wastes
 - **LL** Long Lived,
 - 'Half-life > 30 years
 - Long lived alpha emitters >400Bq/g average
 - >4000Bq/g individual package
 - **SL** Short Lived
 - Half-life <30 years
- **EW** Exempted Wastes

Clearance Levels:
$$L_i = \min \left(\frac{1000}{E_\gamma^i + 0.1 * E_\beta^i}, \frac{D_w}{e_{inh}^i}, \frac{D_w}{e_{ing}^i} \right)$$


Clearance Index :
$$CI = \sum_i^{Radionucleide} \frac{A_i}{L_i}$$

Classification of Radioactive Waste – Safety Series
No 111-G-1.1



ENVIRONMENTAL IMPACT

Activation in molasse



of all the radionuclide's created ^{22}Na and tritium could represent a hazard by contaminating the ground water. Limits in activity after 1y=200days of beam:

- **Outline**
 - **Adapt Study with ESSnuSB Parameters**
 - **Feedback from other experiments crucial !!!**
 - Regular meeting with ESS people in charge of the safety should be organized
 - Safety Meeting between Safety people has been organized at CERN during EUROnu and should be renewed