

Update on the Energy Deposition for the 4horn system


Power for 4horn System, 350kA 1.3MW, Ti packed bed target

studies done with flair 0.9.1 with geoviewer 0.9, fluka 2008.3d



Power in Target Horn Station, 4MW





shielding has to be:

- •extended behind the horns to contain the energy due to particle production and defocusing
- redesigned to include the service galleries

Power scoring parameters:

concrete:

t = 5.3m

L = 8m

P = 109kW

collimator, water cooled (in T2K):

 $t_{Fe} = 60 cm$

 $L_{Fe} = 160cm$


 $P_{Fe} = 266kW$

He vessel, water cooled:


 $t_{Fe} = 10cm$

 $L_{Fe} = 8m$

 $P_{Fe} = 182kW$



Power in Decay tunnel, Beam Dump



He vessel + iron plates, water cooled

$$t_{Fe} = 10-40cm$$

 $L_{Fe} = 6.4m$

upstream shield (iron plates), water cooled

$$t_{Fe} = 40 \text{cm}$$

 $L_{Fe} = 1 \text{m}$

Graphite beam dump:

$$L = 3.2m, W = 4m, H = 4m$$

P= 531kW

downstream iron shield (iron plates), water cooled-


$$L_{Fe} = 40 \text{cm}, W_{Fe} = 4 \text{m}, H_{Fe} = 4 \text{m}$$

 $P_{Fe} = 8.9 \text{kW}$

outer iron shields (iron plates), water cooled

$$L_{Fe} = 2m, W_{Fe} = 4.8m, H_{Fe} = 4.8m$$

 $P_{Fe} = 0.9kW$



Update of Radiation Studies

- dose rates through SB 4horn layout have been calculated but benchmarking is needed
- benchmarking work is ongoing on CNGS target station, see Eric's talk

plans for next weeks

on SB energy

- add service gallery and optimize SB layout
- give first order approximation quantities for concrete, iron ... for costing evaluation

on radiation

benchmark radiation studies

THANKS

